

Coal Combustion Residuals (CCR) Annual Fugitive Dust Control Report

PLANT NAME: Plant McDonough

OWNER/OPERATOR OF FACILITY: Georgia Power

REPORTING TIMEFRAME: October 20, 2023 – October 19, 2024

PURPOSE: The purpose of this report is to demonstrate compliance with the requirements for the annual CCR fugitive dust control report in accordance with Georgia Rules for Solid Waste Management 391-3-4-.10(5) [40 CFR § 257.80 (c)]. This report describes the actions taken by Plant McDonough to control CCR fugitive dust, a record of all citizen complaints and if any, a summary of corrective measures taken.

DESCRIBE THE ACTIONS TAKEN TO CONTROL FUGITIVE DUST.

CCR Units:

Ash Pond 1 (AP-1): closure in place of AP-1 is substantially complete, and CCR is covered by the geomembrane cover system.

Ash Pond 2 (AP-2): CCR has been removed from AP-2 in accordance with the closure plan.

Ash Pond 3 (AP-3): Fugitive dust was controlled by water suppression, chemical dust suppressants, or synthetic liners, as needed.

Ash Pond 4 (AP-4): Fugitive dust was controlled by water suppression, chemical dust suppressants, or synthetic liners, as needed.

Roads, CCR management and material handling activities:

Water suppression was used as needed to control fugitive dust on facility roads used to transport CCR and other CCR management areas.

Speed limits were utilized to reduce the potential for fugitive dust.

Trucks used to transport ash were covered and/or filled at or under capacity to reduce the potential for material spillage.

CCR that was transported via truck on the plant site was conditioned to an appropriate moisture content to reduce the potential for fugitive dust.

HAS THE FACILITY RECEIVED ANY CCR FUGITIVE DUST CITIZEN COMPLAINTS WITHIN THE REPORTING TIMEFRAME?	Yes	<input checked="" type="radio"/> No
----------------------------------------------------------------------------------------------------	-----	-------------------------------------

IF YES, INCLUDE A RECORD OF ALL CITIZEN COMPLAINTS

Date	Description of Complaint	Corrective Measures (If Any)