

**GROUNDWATER EXCEEDANCE NOTIFICATION 40 C.F.R. PART
257.95(g) and GEORGIA EPD RULES FOR SOLID WASTE
MANAGEMENT 391-3-4-.10(6)(a)**

**PLANT MCINTOSH ASH POND
(AP-1)
GEORGIA POWER COMPANY**

Federal and State of Georgia CCR Rule

The following Appendix IV constituent was detected at a statistically significant level above the groundwater protection standard established pursuant to the "Disposal of Coal Combustion Residuals from Electric Utilities" Final Rule, 40 C.F.R.

257.95(h) and Georgia Environmental Protection Division Rules for Solid Waste Management 391-3-4-.10(6)(a).

- **Lithium**

Georgia Power will continue groundwater monitoring and reporting activities required by 40 C.F.R. 257.95.



January 31, 2025

Chad Hall, PhD, P.E.
Georgia Professional Engineer