


257.84 (b)(2)	<b>2024 REPORT OF ANNUAL INSPECTION OF CCR LANDFILL</b>	
	<b>CCR LANDFILL NAME:</b> Plant Scherer Coal Combustion Residuals Landfill (Active Cells 1, PAC/Ash Cell). Permit # 102-009D(CCR).	
	<b>OWNER OF CCR LANDFILL:</b> Georgia Power Company	
	<b>INSPECTION DATE:</b> October 17, 2024	
	<b>INSPECTING ENGINEER:</b> Gary H. McWhorter, P.E. GA Reg. #PE012687	
(i)	<b>ANY CHANGES IN GEOMETRY OF THE STRUCTURE SINCE THE PREVIOUS ANNUAL INSPECTION?</b>	<b>NO</b> <sup>(1)</sup>
	(IF YES, DESCRIBE):	
(ii)	<b>APPROXIMATE VOLUME OF CCR CONTAINED IN THE UNIT AT THE TIME OF INSPECTION?</b>	<b>432,299 yd<sup>3</sup></b> <sup>(2)</sup>
(iii)	<b>ANY APPEARANCE OF AN ACTUAL OR POTENTIAL STRUCTURAL WEAKNESS OF THE CCR UNIT, IN ADDITION TO ANY EXISTING CONDITIONS THAT ARE DISRUPTING OR HAVE THE POTENTIAL TO DISRUPT THE OPERATION AND SAFETY OF THE CCR UNIT?</b>	<b>NO</b>
	(IF YES, DESCRIBE):	
(iv)	<b>ANY OTHER CHANGE(S) WHICH MAY HAVE AFFECTED THE STABILITY OR OPERATION OF THE CCR UNIT SINCE THE PREVIOUS ANNUAL INSPECTION?</b>	<b>NO</b>
	(IF YES, DESCRIBE):	

- (1) The geometry of the structure (permitted footprint and CCR grades) has not changed since the last inspection, with the exception of the additional placement and marketing of CCR.
- (2) Approximate CCR volume (from survey dated 11/22/2024): Cell 1 – 144,766 yd<sup>3</sup>; PAC/Ash Cell – 287,533 yd<sup>3</sup>.


  
 Gary H. McWhorter, P.E.  
 GA Reg. #PE012687  
*Jun 15, 2025*